



Bruhat Bengaluru Mahanagara Palike


No.BBMP/DHO/PR/12/2023-24

Deputy Health Officer
Bommanahalli Zone
BBMP, Bengaluru-68.
Date:20.06.2023.

SAFE DRINKING WATER AND SANITATION CERTIFICATE

This is to certify that the “**ORCHIDS THE INTERNATIONAL SCHOOL**”, situated at #24-39, 7th Main, 4th Cross, Navodhaya Nagara, J.P Nagara, 7th Phase, Bangalore -560 076. Has safe drinking water facilities for the Students and members of staff of the institution is maintaining the hygienic sanitation condition in the school building and The campus as per the norms prescribed by the state Govt. The above valid for a period of 2023-24

The Certificate is issued for the Year 2023-24.


20/6/23
Deputy Health Officer
Bommanahalli Zone
BBMP, Bengaluru-68.
ಬಿ.ಹೆಚ್.ಬಿ.ನಗರ ಪಾಲಿಕೆ

To,
Principal
“**ORCHIDS THE INTERNATIONAL SCHOOL**”
#24-39, 7th Main, 4th Cross,
Navodhaya Nagara, J.P Nagara,
7th Phase, Bangalore -560 076.

GOVERNMENT OF KARNATAKA

No:PHI/Water/BAC/90/23-24

Office of the Joint Director
Public Health Institute
Bangalore - 560 001

Dated: 20-05-2023

Report of Bacteriological analysis of Water / Effluent sample

Sample sent by:	Opinion					S.P.P	N.S.P.P	N.S.P.P & FC.
	Sample No	Source & Particulars of Water Sample	M.P.N Count	Plate Count	D.C Test			
Orchids, The International School #24, 7 th main, 4 th Cross, Navodaya Nagar, J.P. Nagar, 7 th Phase, Bangalore.	288	RO	Nil	-	-	SPP	-	-
Note: M.P.N Count: Most probable number of Bacteria per 100ml of Water D.C Test: Differential Coliform test Plate Count: Plate Count per ml of sample SPP: Water is satisfactory for Potable purpose NSPP: Water is not satisfactory for Drinking purpose NSPP & FC: Water is not satisfactory for Drinking purpose and E. Coli found.								

For Joint Director(Labs)
PUBLIC HEALTH INSTITUTE
Bangalore

Advice:

1. Sample.....

Need effective chlorination before use

2. Sample.....

Need to avoid possible source of faecal contamination and effective chlorination before use
For the purpose of chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform count per 100ml	E. coli count per 100ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or more